Revised Ordinance passed 03-18-23 Originally passed 02-10-18 Policy 10-01-12

MODEL ORDINANCE NO. 2 - ABBREVIATED VERSION

AN ORDINANCE OF THE **Big Lagoon Community Services District**

(BLCSD)

INSTITUTING A CROSS-CONNECTION CONTROL ROGRAM TO PROTECT THE PUBLIC WATER SYSTEM

THE {Water Supplier} DOES ORDAIN AS FOLLOWS:

SECTION I - PURPOSE

The purpose of this ordinance is to protect the public water supply system from contamination due to potential and actual cross-connections. This shall be accomplished by the establishment of a cross-connection control program as required by State regulations. This ordinance is adopted pursuant to Title 17, section 7583 - 7605, inclusive, of the California Code of Regulations, entitled "Regulations Relating to Cross-Connections".

New Construction-2016 California Plumbing Code 602.3 Backflow Prevention

No plumbing fixture, device, or construction shall be installed or maintained, or shall be connected to a domestic water supply, where such installation or connection provides a possibility of polluting such water supply or cross connection between a distributing system of water for drinking and domestic purposes and water that becomes contaminated by such plumbing fixture, device, or construction unless there is provided a backflow prevention device approved for the potential hazard.

SECTION II - **RESPONSIBILITY**

The {Chair/cross-connection control specialist} shall be responsible for implementing and enforcing the cross-connection control program. An appropriate backflow prevention assembly shall be installed by and at the expense of the water user at each user connection where required to prevent backflow from the water user's premises to the domestic water system. It shall be the water User's responsibility to -comply with the {Water Supplier}'s requirements.

SECTION III - CROSS-CONNECTION PROTECTION REQUIREMENTS

The type of protection-that shall be provided to prevent backflow into the public water supply system shall be commensurate with the degree of hazard, actual or potential, that exists on the water user's premises. Unprotected cross-connections with the public water supply are prohibited. The type of backflow prevention assembly that may be required, (listed in decreasing level \cdot of protection), includes: Air-gap separation (AG), Reduced Pressure Principal Backflow Prevention Assembly (RP), and a Double Check Valve Assembly (DC). The water user may choose a higher level of protection than required by the water supplier. The minimum types of backflow protection required to protect the approved water supply at the user's water connection to premises with varying degrees of hazard are listed in Table 1 of Section 7604, Title 17. Situations which are not covered in Table 1 shall be evaluated on a case-by-case basis and the appropriate backflow protection shall be determined by the water supplier or health agency.

SECTION IV - BACKFLOW PREVENTION ASSEMBLIES

Only backflow prevention assemblies which have been approved by the {Water Supplier} shall be acceptable for installation by a water user. A list of approved backflow prevention assemblies

will-be provided upon request to any affected customer. Backflow prevention assemblies shall be installed in a manner prescribed in section 7603, Title 17. Location of the assemblies shall be as close as practical to the user's connection. The {Water supplier} shall have the final authority in determining the required location of a backflow prevention assembly.

Testing of backflow assemblies shall be conducted only by qualified testers. BLCSD will conduct at District expense annual testing for service connections located within the geographic borders of the CSD. Owners of service connections located outside of the BLCSD borders can either choose their own approved vendor or BLCSD will invoice the owner of the service connection the cost of testing. Backflow prevention assemblies must be tested at least annually and immediately after installation, relocation, or repair. More frequent testing may be required if deemed necessary by the (Water Supplier). No assembly shall be placed back in service unless it is functioning as required. These assemblies shall be serviced, overhauled, or replaced whenever they are found to be defective and all costs of repair, and maintenance shall be borne by the water user. Approval must be obtained from the

{Water Supplier} prior to removing, relocating, or replacing a backflow prevention assembly.

SECTION VI - ADMINISTRATION

The cross-connection control program shall be administered by the {General Manager/cross-connection control specialist}. The {Water Supplier} will establish and maintain a list of approved backflow prevention assemblies as well as a list of approved backflow prevention assembly testers. The {Water Supplier} shall conduct necessary surveys of water user premises to evaluate the degree of potential health hazards. The {Water Supplier} shall notify users when an assembly needs to be tested. The notice shall contain the date when the test must be completed.

Revised Ordinance passed 03-18-23 Originally passed 02-10-18 Policy 10-01-12

SECTION VII - WATER SERVICE TERMINATION

When the {Water Supplier} encounters water uses that represent a clear and immediate hazard to the potable water supply that cannot be immediately abated, the procedure for terminating water service shall be instituted. Conditions or water uses that create a basis for water service termination shall include, <u>BUT ARE NOT</u> LIMITED TO the Following:

- 1.Refusal to install or to test a backflow prevention assembly, or to repair or replace a faulty backflow prevention assembly.
- Direct or indirect connection between the public water system and a sewer line.
- Unprotected direct or indirect connection between the public water system and a system or equipment containing contaminants.
 - 4. Unprotected direct or indirect connection between the public water system and an auxiliary water system.

For condition 1, the {Water Supplier} will terminate service to a water user's premises after proper notification has been sent. If no action is taken within the allowed time period water service shall be terminated.

For conditions 2, 3, or 4, the {Water Supplier} shall take the following steps:

- Make reasonable effort to advise the water user of intent to terminate water service;
- Terminate water service and lock service valve. The water service shall remain inactive until correction of violations has been approved by the {Water Supplier}.

SECTION VII - EFFECTIVE DATE

This Ordinance shall supersede all previous crossconnection control ordinances and shall take effect immediately upon adoption. The ordinance will be posted on the Governance page under policies on the BLCSD website at www.Biglagooncsd.org.